



PRAKAB PRAŽSKÁ KABELOVNA

DECLARATION OF PERFORMANCE

No.703492/2017

- | | | | |
|--|---|------------------------------------|-------------------|
| 1. Unique identification code of the product-type: | Telecommunication, control and installation cable PRAFlaCom F (circular solid cooper conductor, dimensions 1 ÷ 10 x 2 x 0,8) | | |
| 2. Intended use/es: | Telecommunication, control and installation in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke | | |
| 3. Manufacturer: | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kable 278
102 00 Prague 10 (HOSTIVAŘ)
Czech republic | | |
| 4. Authorised representative: | - | | |
| 5. System/s of AVCP: | 1+ | | |
| 6. Harmonised standard: | EN 50575:2014+A1:2016 | | |
| Notified body/ies: | No. 1014
Electrotechnical testing institute
Pod Lisem 129
171 02 Prague 8 – Troja
Czech republic | | |
| 7. Declared performance/s: | Reaction to fire | B2_{ca}- s1, d0, a1 | |
| | Dangerous substances | NPD | |
| Appropriate Technical Documentation and/or Specific Technical Documentation: | Certificate No. | 1014-CPR-0049 | from 24. 11. 2017 |
| | Classification report No. | 703492-01/01 CLASS | from 22. 11. 2017 |
| | Test report | 703492-01/01 | from 21. 11. 2017 |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 28. 11. 2017

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO