



PRAKAB PRAŽSKÁ KABELOVNA

DECLARATION OF PERFORMANCE

No.801044/2018

- | | |
|--|--|
| 1. Unique identification code of the product-type: | Power cables with special fire performance PRAFlaSafe + AX (multicore, circular aluminium conductor, class 1 or 2) |
| 2. Intended use/es: | Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke |
| 3. Manufacturer: | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kablu 278
102 00 Prague 10 (HOSTIVÁŘ)
Czech republic |
| 4. Authorised representative: | - |
| 5. System/s of AVCP: | 1+ |
| 6. Harmonised standard: | EN 50575:2014+A1:2016 |
| Notified body/ies: | No. 1014
ELECTROTECHNICAL TESTING INSTITUTE
Pod lisem 129/2
171 02 Praha 8 – Troja
Czech republic |
| 7. Declared performance/s: | Reaction to fire B2_{ca}-s1a, d1, a1
Dangerous substances NPD |
| Appropriate Technical Documentation and/or Specific Technical Documentation: | Certificate No. 1014-CPR-0094 from 25. 9. 2018
Classification report No. 801044-01/01 CLASS from 20. 9. 2018
Test report 801044-01/01 from 14. 9. 2018 |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 2.10.2018

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO