



PRAKAB PRAŽSKÁ KABELOVNA

## DECLARATION OF PERFORMANCE

No.605684/2017

- |   |   |
|---|---|
| 1. Unique identification code of the product-type:                              | Power cables with special fire performance PRAFlaSafe X (multicore – circular copper conductor, class 1 or 2)   |
| 2. Intended use/es:   | Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke   |
| 3. Manufacturer:  | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.<br>Ke Kablu 278<br>102 00 Praha 10 (HOSTIVAŘ), Czech republic  |
| 4. Authorised representative:   | -   |
| 5. System/s of AVCP:  | 1+  |
| 6. Harmonised standard:   | EN 50575:2014+A1:2016   |
| Notified body/ies:  | No. 1014<br>ELECTROTECHNICAL TESTING INSTITUTE<br>Pod lisem 129/2<br>171 02 Praha 8 – Troja, Czech republic   |
| 7. Declared performance/s:  | Reaction to fire <b>B2<sub>ca</sub>- s1a, d1, a1</b><br>Dangerous substances <b>NPD</b><br>Certificate No. 1014-CPR-0033 from 31. 07. 2017<br>Certificate No. 1014-CPR-0113 from 22. 05. 2019 |
| 8. Appropriate Technical Documentation and/or Specific Technical Documentation: | Classification report No. 604684-01/01 CLASS from 10. 05. 2019<br>Test report 604684-01/01 from 10. 07. 2017<br>Test report 910858-01/01 from 30. 04. 2019                                    |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 30.5.2019

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO