



PRAKAB PRAŽSKÁ KABELOVNA

DECLARATION OF PERFORMANCE

No.801029/2018

1. Unique identification code of the product-type: Power cables with special fire performance AXQJ EMC
2. Intended use/es: Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke
3. Manufacturer: PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kablu 278
102 00 Prague 10 (HOSTIVÁŘ)
Czech republic
4. Authorised representative: -
5. System/s of AVCP: 3
6. Harmonised standard: EN 50575:2014+A1:2016
- Notified body/ies: No. 1014
ELECTROTECHNICAL TESTING INSTITUTE
Pod lísem 129/2
171 02 Praha 8 – Troja
Czech republic
7. Declared performance/s: Reaction to fire **D_{ca}- s2, d2, a1**
Dangerous substances NPD
8. Appropriate Technical Documentation and/or Specific Technical Documentation: Classification report No. 801029-01/01 CLASS from 24. 4. 2018
Test report 801029-01/01 from 20. 4. 2018

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 26.4.2018

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO