



## No.801027/2018

- |    |  |   |                    |                  |
|----|--|---|--------------------|------------------|
| 1. | Unique identification code of the product-type:                              | Power cable PRAZov<br>(multicore, circular copper conductor)  |                    |                  |
| 2. | Intended use/es:   | Supply of electricity   |                    |                  |
| 3. | Manufacturer:  | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.<br>Ke Kable 278<br>102 00 Praha 10 (HOSTIVÁŘ)<br>Czech republic              |                    |                  |
| 4. | Authorised representative:   | -   |                    |                  |
| 5. | System/s of AVCP:  | 3   |                    |                  |
| 6. | Harmonised standard:   | EN 50575:2014+A1:2016   |                    |                  |
|    | Notified body/ies:   | No. 1014<br>ELECTROTECHNICAL TESTING INSTITUTE<br>Pod lisem 129/2<br>171 02 Praha 8 – Troja<br>Czech republic |                    |                  |
| 7. | Declared performance/s:  | Reaction to fire  | E <sub>ca</sub>    |                  |
|    |  | Dangerous substances  | NPD                |                  |
| 8. | Appropriate Technical Documentation and/or Specific Technical Documentation: | Classification report No.   | 801027-01/01 CLASS | from 12. 6. 2018 |
|    |  | Test report   | 801027-01/01       | from 29. 5. 2018 |

Date of issue: 28.6.2018

Ing. Tomáš Zieschang, Ph.D.,

Managing director, CEO

Managing director, CFO