



PRAKAB PRAŽSKÁ KABELOVNA

DECLARATION OF PERFORMANCE

No.701173/2017

1. Unique identification code of the product-type: Power cables with special fire performance CH-N1Z1Z1 (multicore – circular copper conductor, class 1, 2)
2. Intended use/es: Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke
3. Manufacturer: PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kablu 278
102 00 Praha 10 (HOSTIVARĚ), Czech republic
4. Authorised representative: -
5. System/s of AVCP: 1+
6. Harmonised standard: EN 50575:2014+A1:2016
- Notified body/ies: No. 1014
ELECTROTECHNICAL TESTING INSTITUTE
Pod lisem 129/2
171 02 Praha 8 – Troja, Czech republic
7. Declared performance/s:
Reaction to fire **B2_{ca}- s1, d1, a1**
Dangerous substances NPD
Certificate No. 1014-CPR-0083 from 3. 5. 2018
8. Appropriate Technical Documentation and/or Specific Technical Documentation: Classification report No. 701173-01/01 CLASS from 20. 4. 2018
Test report 701173-01/01 from 9. 5. 2017
Test report 704672-01/01 from 16. 4. 2018

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 16. 5. 2018

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO