



PRAKAB PRAŽSKÁ KABELOVNA

DECLARATION OF PERFORMANCE

No.700270/2017

1. Unique identification code of the product-type: Power cables with special fire performance AXQJ
2. Intended use/es: Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke
3. Manufacturer: PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.
Ke Kable 278
102 00 Praha 10 (HOSTIVÁŘ)
Czech republic
4. Authorised representative: -
5. System/s of AVCP: 1+
6. Harmonised standard: EN 50575:2014+A1:2016
- Notified body/ies: No. 1014
Elektrotechnický zkušební ústav, s. p.,
Pod Lisem 129, Praha 8 – Troja, Česká Republika
7. Declared performance/s: Reaction to fire **D_{ca}- s2, d2, a1**
Dangerous substances NPD
Certificate No. 1014-CPR-0013 from 23. 2. 2017
8. Appropriate Technical Documentation and/or Specific Technical Documentation: Classification report No. 700270-01/01 CLASS from 23. 2. 2017
Test report 700270-01/01 from 20. 2. 2017

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 27.2.2017

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO