

DECLARATION OF PERFORMANCE

No.701876/2017

Unique identification code of the product-type:

Power cables with special fire performance N2XH (multicore, sector shaped copper conductor, class 1, 2)

Intended use/es:

Manufacturer:

Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke

PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.

Ke Kablu 278

102 00 Praha 10 (HOSTIVAŘ), Czech republic

Authorised representative:

System/s of AVCP:

1+

Harmonised standard:

EN 50575:2014+A1:2016

No. 1014

Notified body/ies:

ELECTROTECHNICAL TESTING INSTITUTE

Pod lisem 129/2

171 02 Praha 8 - Troja, Czech republic

Reaction to fire

Certificate No.

Cca- s1a, d1, a1

1014-CPR-0025

Declared performance/s:

Dangerous substances

from 2. 6. 2017

Certificate No.

1014-CPR-0096

NPD

from 25. 9. 2018

Appropriate Technical Documentation

8. and/or Specific Technical

Documentation:

Classification report No. 701876-01/01 CLASS from 20. 9. 2018

Test report

701876-01/01

from 1. 6. 2017

Test report

802736-01/01

from 14. 9. 2018

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place:

Prague

Date of issue:

2.10.2018

Signed for and on behalf of the

manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO

tel. +420 272 070 210 I office@prakab.cz I www.prakab.cz