



PRAKAB PRAŽSKÁ KABELOVNA

## DECLARATION OF PERFORMANCE

No.701877/2017

- |                                                                              |                                                                                                                                                           |
|------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1. Unique identification code of the product-type:                           | Power cables with special fire performance N2XH (single core – circular copper conductor, class 1 or 2)                                                   |
| 2. Intended use/es:                                                          | Supply of electricity in buildings and other engineering works with the objective of limiting the generation and spread of fire and smoke                 |
| 3. Manufacturer:                                                             | PRAKAB PRAŽSKÁ KABELOVNA, s.r.o.<br>Ke Kablu 278<br>102 00 Prague 10 (HOSTIVAŘ)<br>Czech republic                                                         |
| 4. Authorised representative:                                                | -                                                                                                                                                         |
| 5. System/s of AVCP:                                                         | 1+                                                                                                                                                        |
| 6. Harmonised standard:                                                      | EN 50575:2014+A1:2016                                                                                                                                     |
| Notified body/ies:                                                           | No. 1014<br>Electrotechnical testing institute<br>Pod Lisem 129<br>171 02 Prague 8 – Troja<br>Czech republic                                              |
| 7. Declared performance/s:                                                   | Reaction to fire <b>C<sub>ca</sub>- s1, d2, a1</b><br>Dangerous substances NPD                                                                            |
| Appropriate Technical Documentation and/or Specific Technical Documentation: | Certificate No. 1014-CPR-0026 from 2. 6. 2017<br>Classification report No. 701877-01/01 CLASS from 2. 6. 2017<br>Test report 701877-01/01 from 1. 6. 2017 |

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Place: Prague

Date of issue: 13. 6. 2017

Signed for and on behalf of the manufacturer by:

Ing. Tomáš Zieschang, Ph.D.

Function:

Managing director, CEO

Ing. Jaroslav Krňák

Managing director, CFO